

11/05/2008 11:34

9547540550

ALLAN A KOZICH

ALLAN A KUZLUM

PAGE 02/04

10/27/2008 11:48

9547351007

PAGE 01

3:16-28-2008 THU 02:19 PM

P. 002

### CITIZENS PROPERTY INSURANCE CORPORATION BUILDING TYPE II AND III MITIGATION VERIFICATION AFFIDAVIT

This affidavit must be completed to ensure mitigation features applicable to a Type II (4 to 6 story) or Type III (7 or more story) building. This affidavit is required for either residential condominium unit owners or commercial residential applicants requesting mitigation credits in such buildings.

WIND LOSS MITIGATION INFORMATION		
PREMIER #	SUBJECT OF INSURANCE	POLICY #
BUILDING #	STREET ADDRESS: 750 N. OCEAN BLVD. POMPANO BEACH	
# STORIES: 120	BLDG DESCRIPTION: ADMIRALTY TOWERS	
BUILDING TYPE: <input type="checkbox"/> II (4 to 6 stories) <input checked="" type="checkbox"/> III (7 or more stories)		

Terrain Exposure Category must be provided for each insured location.

I hereby certify that the building or unit at the address indicated above THROUGH EXPOSURE CATEGORY as defined under the Florida Building Code is (Check One):  Exposure C or  Exposure B

Certification below for purposes of TERRAIN EXPOSURE CATEGORY above does not require personal inspection of the premises.

Certification of Wind Speed is required to establish the basic wind speed of the location. (Complete for Terrain B only if Year Built On or After Jan. 1, 2002).

I hereby certify that the basic WIND SPEED of new building or unit at the address indicated above based upon county wind speed lines defined under the Florida Building Code (FBC) is (Check One):  2100 or  2110 or  2120

Certification of Wind Design is required when the building is constructed in a manner to exceed the basic wind speed design established for the structure location. (Complete for Terrain B only if Year Built On or After Jan. 1, 2002).

I hereby certify that the building or unit at the address indicated above is designed and mitigated to the Florida Building Code (FBC) WIND DESIGN of (Check One):  2100 or  2110 or  2120

Certification for the purpose of establishing the basic WIND SPEED or WIND SPEED DESIGN above does not require personal inspection of the premises.

Specify the type of mitigation device(s) installed:

**Roof Coverings**

- Reinforced Concrete Roof - Type II or III  
A roof structure composed of cast-in-place or pre-cast structural concrete designed to be self-supporting and integrally attached to wall/support system.
- Level A (Non FBC Equivalent) - Type II or III  
All roof cover types and configurations that do not meet Level B below.
- Level B (FBC Equivalent) - Type II or III  
Roof coverings must satisfy all of the following conditions and are one of the following types:
  1. Built-up - Cold Tar w/ GRAVEL
  2. Modified Bitumen
  3. Sprayed Polyurethane foam
  4. Liquid membrane applied over concrete
  5. Asphalt roll roofing
  6. Wood shakes in good condition, attached with at least two mechanical fasteners
  7. Ballasted roof designed to meet the design wind speed requirements
  8. Asphalt roof coverings installed in accordance ASTM E 9981 (modified for 115 mph) or Miami Dade County MA 107-06.

All mechanical equipment must be adequately tied to the roof deck to resist uprooting and lifting during high winds. All the roof covering with fastening or sealing must be mechanically attached to the structure with fasteners (no clip-on systems); and roof coverings on flat roofs must be 10 years old or less.

11/19/2008 14:02 9547351007

11/05/2008 11:34 9547640560

ALLAN A KOZICH

PAGE 02

PAGE 03/04

RECEIVED 10/27/2008 12:49 9547640560

ALLAN A KOZICH

10/27/2008 11:48 9547351007

PAGE 02

AUG-28-2008 THU 02:19 PM

P. 003

### CITIZENS PROPERTY INSURANCE CORPORATION BUILDING TYPE II AND III MITIGATION VERIFICATION AFFIDAVIT

**Roof Deck Attachment**

**Level A - Wood or Other Deck Type II only**  
Roof deck composed of sheets of structural panels (plywood or OSB).  
Or  
Architectural (non-structural) metal panels that require a solid decking to support weight and loads.  
Or  
Other roof decks that do not meet Levels B or C below.

**Level B - Metal Deck Type II or III**  
Metal roof deck made of structural panels that span from joint to joint.

**Level C - Reinforced Concrete Roof Deck Type, II or III**  
A roof structure composed of cast-in-place or pre-cast structural concrete designed to be self-supporting and integrally attached to wall/support system.

**Secondary Water Resistance**

**Underlayment**  
A self-adhering polymer modified bitumen roofing underlayment (thin rubber sheets with peel and stick underlayment) beneath the roof covering and normal felt underlayment with a minimum width of 5' meeting the requirements of ASTM D 1870 installed over all plywood/OSB joints to protect from water intrusion. All secondary water resistance products must be installed per the manufacturer's recommendations. Roofing felt or similar paper based products are not acceptable for secondary water resistance.

**Formed Adhesive**  
A formed polyurethane sheathing adhesive applied over all joints in the roof sheathing to protect interior from water intrusion.

**Opening Protection**

**Class A (Hurricane Impact) - All glazed openings (windows, skylights, sliding glass doors, doors with windows, etc) less than 60 feet above grade must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the requirements of:**  
 SSTO12;  ASTM E 1888 and ASTM E 1596 (Missile Level C - 8 lb);  
 Miami-Dade PA 201, 202, and 203; or  Florida Building Code TAS 201, 202 and 203.  
All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. All glazed openings less than 30 feet above grade shall meet the Large Missile Test of the respective standard.

**Class B (Basic Impact) - All glazed openings (windows, skylights, sliding glass doors, doors with windows, etc) must be protected with impact resistant coverings (e.g. shutters), impact resistant doors, and/or impact resistant glazing that meet the requirements of:**  
 ASTM E 1888 and ASTM E 1596 (Missile Level B - 4.5 lb)  
All glazed openings between 30 and 60 feet above grade must meet the Small Missile Test of the respective standard. All glazed openings less than 30 feet above grade shall meet the Large Missile Test of the respective standard.

11/19/2008 14:02 9547351007

11/05/2008 11:34 9547540560

RECEIVED 10/27/2008 12:48

ALLAN A KOZICH  
9547540560

ALLAN A KOZICH

PAGE 03

PAGE 04/04

10/27/2008 11:48 9547951007

NOV 20 2008 10 02:19 PM

PAGE 03

P. 004

**CITIZENS PROPERTY INSURANCE CORPORATION**  
**BUILDING TYPE II AND III MITIGATION VERIFICATION AFFIDAVIT**

**CERTIFICATION**

I certify that I am (CHECK ONE OF THE FOLLOWING):

a resident/licensed General, or Building Contractor,  a Licensed Building Inspector,  a Registered Architect,  an Engineer in the State of Florida,  a Building Code Official (who is duly authorized by the State of Florida or its county's municipalities to verify building code compliance).

I also certify that I personally inspected the premises at the Location Address listed above on the date of this Affidavit. In my professional opinion, based on my knowledge, information and belief, I certify that the above statements are true and correct.

This Affidavit and the information set forth in it are provided solely for the purpose of verifying that certain structural or physical characteristics exist at the Location Address listed above and for the purpose of permitting the Member Insured to receive a possible insurance premium discount on insurance provided by Citizens Property Insurance Corporation and for no other purpose. The undersigned does not make a health or safety certification or warranty, express or implied, of any kind, and nothing in this Affidavit shall be construed to impose on the undersigned or on any entity to which the undersigned is related any liability or obligation of any nature to the named Insured or to any other person or entity.

Name of Company: Allan A. Kozich & Associates Phone: 954-764-0535

Name of Inspector: Allan A. Kozich License Type: P.E. License #: 16864

Date: 11/03/2008

Signature: [Handwritten Signature]

Applicant's Signature: [Handwritten Signature] Date: 11-5-2008

"Any person who knowingly and with intent to injure, defraud, or deceive any Insured files a statement of claim or an application containing any false, incomplete, or misleading information is guilty of a felony of the third degree."